

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7125-1130:171 Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** Honeywell International Inc., 1500 W. Dundee Rd., Arlington Heights, IL 60004-1472  
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

**DESIGN:** Models XLS757-3A-CS, XLS757-5A-CS, XLS757-7A-CS and XLS757-8A-CS chime strobes. Unit may be followed by A through Z to indicate product color. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Candela: -5A: 15cd  
-3A: 30cd  
-7A: 15/75cd  
-8A: 110cd  
  
Electrical: 20-24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, candela/electrical rating and UL label.

**APPROVAL:** Listed as chime strobes suitable for the hearing impaired when used in conjunction with separately listed electrically and functionally compatible fire alarm control units. For indoor use only.  
  
If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**XLf:** \*7125-1591:178 Formerly 7125-1388:202

\*Rev. 05-24-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager